



EBNV.E162473 Conduit Fittings for Use in Hazardous Locations

[Page Bottom](#)

Conduit Fittings for Use in Hazardous Locations

[See General Information for Conduit Fittings for Use in Hazardous Locations](#)

TECNA S A

E162473

Cra. 32 No. 22B-66

Bogota, DC COLOMBIA

Class I, Groups C and D; Class II, Groups E, F and G.

Conduit union, Cat. No. SX2UN followed by F, Y, FA or YA, followed by 150 or 200, conduit sizes 1-1/2 and 2 in.NPT respectively.

Conduit fitting for sealing, Cat. No. SX1EY followed by -A, -AM, -AA or -AAM followed by -050, -075, -100, -200, -250, -300 or -400, conduit sizes 1/2, 3/4, 1, 2, 2-1/2, 3 or 4 in. respectively.

Conduit union, Cat. No. SX2UN followed by F, Y, FA or YA followed by -050, -075, -100, -250, -300 and -400, conduit sizes 1/2, 3/4, 1, 2-1/2, 3 and 4 in.NPT respectively.

Class I, Group D; Class II, Groups E, F and G.

Conduit fitting for sealing, Cat. No. SX1EY followed by -A, -AA, -AM, or -AAM, followed by -150, conduit sizes 1-1/2 in.

[Last Updated](#) on 2014-06-18

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".